


NOTES :

1. SOFT METAL PIPE FLASHING:
 - SHEET LEAD: MINIMUM OF 2 1/2 LB. PER SQUARE FOOT [12 kg/m²] OR
 - SHEET COPPER: MINIMUM 16 OZ. [5 kg/m²]
2. IF USING COPPER FLASHING OVER AN IRON OR STEEL PIPE, INSERT A SEPARATOR SHEET (E.G., ASPHALT-SATURATED ROOFING FELT), WRAPPED AROUND PIPE, TO SEPARATE THE COPPER FLASHING FROM DIRECT CONTACT WITH PIPE, TO REDUCE GALVANIC ACTION.
3. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES [300 mm] OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING. SEE TABLE 4.
4. REFER TO INTRODUCTION FOR ADDITIONAL INFORMATION.

	<p>NATIONAL ROOFING CONTRACTORS ASSOCIATION</p>	<p>PLUMBING VENT</p>	<p>BUR-18</p>
	<p>2001</p>	<p>NOT DRAWN TO SCALE</p>	