


NOTES :

1. THIS DETAIL ACCOMMODATES INDEPENDENT DECK AND PENETRATION MOVEMENT.
2. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES [300 mm] OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING.



**NATIONAL  
ROOFING  
CONTRACTORS  
ASSOCIATION**

**NON-DECK SUPPORTED PENETRATION**

2001

NOT DRAWN TO SCALE

**SPF-19**