


NOTES :

1. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES [300 mm] OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING. SEE TABLE 4.
2. REFER TO THE INTRODUCTON FOR ADDITIONAL INFORMATION.



**NATIONAL
ROOFING
CONTRACTORS
ASSOCIATION**

PLUMBING VENT (FIELD WRAP)

2001

NOT DRAWN TO SCALE

TP-18